



TOWNSHIP OF CRANFORD BOROUGH OF GARWOOD

GAS PIPING REQUIREMENTS



The installation of all gas piping shall comply with the standards as set forth in accordance to the 2015 International Fuel Gas Code.



No permit Application will be accepted without a riser diagram of the gas piping system. (The length of pipe from the point of delivery to the most remote outlet and all branch outlets.) Also include the total **BTU** rating of each appliance and indicate on the drawing **all pipe type & sizes**.

CSST INSTALLATIONS:

The following is required for permit applications whether the installation involves new install or extension of existing that includes CSST piping:

1. A copy of the installer's certification from the manufacturer for the installation of CSST.
2. An electrical permit is required for the bonding of CSST

Example:



Bonding of CSST can be done to any of the following locations:

1. Cold Water Meter
2. Ground Rod
3. Footing Bond
4. Electric Panel*

*Not Recommended